

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 610

Dated: 17/03/2025

It is certified that an inspection team headed by Er. Vinminder Singh SDE, No. 4 HSP
 (Name of Officers with designation) from Water Supply & Sanitation Deptt. HSP,
 (Name of Department/ Office) inspected the Academic Heights Public School,
 (Name & Address of the school) on 12-03-25 (date of inspection) and found that the
Academic Heights Public School (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 1 year from date of Issue of Certificate.

Signature with Seal: 

Name

Er. Vinminder Singh

Designation

Sub Divisional Engineer,Name & Address of the Office / Department: Sub Div. No. 4,W/S + SanitationHoshiarpur.

To

Academic Heights,
Public School,V.P.O. Chagran, Chandigarh Rd,
Hoshiarpur,

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate


Principal
Academic Heights Public School
Hoshiarpur


Chairman
Academic Heights Public School
Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwthsp@gmail.com

To,

Academic Heights Public School
V.P.O. Chagran, Chandigarh Road, Hoshiarpur (Punjab)

No.: RWTLHSP/2425/00645 Dated : 10/03/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. AHPS/06/2025 Dated: 05/03/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 05/03/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : 1 Test Report



Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur


Chairman
Academic Heights Public School
Hoshiarpur


Principal
Academic Heights Public School
Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com



TC-12884

TEST REPORT

Name & Address of Customer : Academic Heights Public School V.P.O. Chagran, Chandigarh Road, Hoshiarpur (Punjab)		Customer Reference No.	No : AHPS/06/2025 Dated : 05/03/2025	
		Sample Submitted by	Jagdish Lal Mehta	
		Date of Sample Receipt	05/03/2025	
		Analysis Starting Date	05/03/2025	
		Analysis completion Date	07/03/2025	
Discipline : Chemical Testing		Group: Water		
ULR No.:	TC12864250000072F	Sample Type :	Water	
Test Report No.:	RWTLHSP/2425/00645	Date of Issue :	10/03/2025	
Registration no.:	RWTLHSP/REG2425/04082	Condition of Sample :	Unsealed	
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Academic Heights Public School, Hoshiarpur / NA	
Village :	Chaggran	Habitation :	Chaggran	
Block:	Hoshiarpur-II	District :	Hoshiarpur	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.68@24°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	90.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	67.66	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	72.72	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	12.95	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	9.83	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	8.11	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Ravinder
Principal
Academic Heights Public School
Hoshiarpur

Jagdish Lal Mehta
Chairman
Academic Heights Public School
Hoshiarpur

Reviewed and Approved By

Abhishek Joshi
Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

End of the Test Report

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

Payment Receipt

Receipt No. : 22248

Date : 05/03/2025

Invoice No. : INV/2425/00648

Invoice Date : 05/03/2025

Received From : Academic Heights Public School
V.P.O. Chagran, Chandigarh Road, Hoshiarpur (Punjab)

The Sum of Rupees : Three Hundred Thirty Only.

In Cash

Rs. : 330.00

Disclaimer: -Payment made by cheque/online mode are subject to clearance by bank.

Okaur
वेतल पानी कोशक प्रयोग
नए प्रयोगों के लिए
011-26660000

For Regional Water Testing Lab, Hoshiarpur
Authorized Signatory

P. Dhillon
Principal
Academic Heights Public School
Hoshiarpur

Amit Mehta
Chairman
Academic Heights Public School
Hoshiarpur