

Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 723

Date: 3-6-26

It is certified that an inspection team headed by Vinnider Singh (S.D.E) (Name of Officers with designation) From W/S Sanitation Sub Division No-4 HSP PHED Inspected the Academic Heights Public School, VPO: Chagran, Chandigarh Road, Hoshiarpur (Name & Address of the school) on 03-05-2026 (date of Inspection) and on the basis of Water Test Report (Attached) Bearing No. RWTLHSP/2627/00034 dated 16-04-2026 of Regional Water Testing Lab, Hoshiarpur (PHED Lab) certified that the Academic Heights Public School (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till 03-05-2027.

Signature with Seal:  Sub Divisional Engineer
Water Supply & Sanitation S/D No. 4,
Hoshiarpur

Name: Er. Vinnider Singh

Designation: Sub divisional Engineer

Name and address of the Office/Department:
W/S and Sanitation Sub Division
No - 4 Hoshiarpur

To

Academic Heights Public School
VPO: Chagran, Chandigarh Road, Hoshiarpur
(Name & Address of the Institution)


Manager
Academic Heights Public School
Hoshiarpur


Principal
Academic Heights Public School
Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwthsp@gmail.com

To,

Academic Heights Public School
V.P.O. Chagran, Chandigarh Road, Hoshiarpur (Punjab)

No.: RWTLHSP/2627/00034 Dated : 16/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Spl-1 Dated: 15/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 15/04/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur



Manager
Academic Heights Public School
Hoshiarpur



Principal
Academic Heights Public School
Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

TEST REPORT

Name & Address of Customer : Academic Heights Public School V.P.O. Chagran, Chandigarh Road, Hoshiarpur (Punjab)	Customer Reference No.	No : Spl-1 Dated : 15/04/2026
	Sample Submitted by	Jagdish Lal Mehta
	Date of Sample Receipt	15/04/2026
	Analysis Starting Date	15/04/2026
	Analysis completion Date	16/04/2026
Discipline : Chemical Testing, Bacteriological Testing		Group: Water
ULR No.:		Sample Type : Water
Test Report No.:	RWTLHSP/2627/00034	Date of Issue : 16/04/2026
Registration no.:	RWTLHSP/REG2627/00052	Condition of Sample : Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle: 1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : Academic Heights Public School / NA
Village :	Chaggran	Habitation : Chaggran
Block:	Hoshiarpur-II	District : Hoshiarpur
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.67@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	105.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	67.32	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	83.16	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	12.70	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	12.51	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	9.86	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method
12	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method
13	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method

Continue on next page...

Vene Kumar
Manager

Academic Heights Public School
Hoshiarpur

Principal
Principal
Academic Heights Public School
Hoshiarpur

Reviewed and Approved By

Abhishek Joshi

Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

14	Bacteriological Contamination(B)	ABSENT				H2S Vial
----	----------------------------------	--------	--	--	--	----------

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS - Total Dissolved Solids, mg/l - milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$


Reviewed and Approved By



Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

End of the Test Report


Principal
Academic Heights Public School
Hoshiarpur


Manager
Academic Heights Public School
Hoshiarpur